

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 11:54 am

**PWS ID:** UTAH08024      **Name:** GOBLIN VALLEY STATE PARK  
**Legal Contact:** UTAH STATE PARKS SOUTHEAST REGI      **Rating:** Approved  
TIM SMITH      **Rating Date:** 04/09/1996  
**Address:** 1165 S HWY 191 SUITE 7      **Activity Status:** Active  
MOAB, UT 84532-3062  
**Phone Number:** 435-259-3750  
**City Served (Area):**  
**County:** EMERY COUNTY  
**System Type:** Non-community      **Last Inv Update:** 08/01/2010      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 10/12/2007      **Total Dsgn Cap:**  
**Population:** 1,000      **Surveyor:** GARY XANTHOS      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

Gal/Day    Gal/Min

### Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	SMITH, TIM	SE REGION MA	435-259-3750		TIMSMITH@UTAH.GOV

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unmetered	0	28
			28    Total Svc Connections

### Storage

**Total Storage:** 20,000 GAL      **Number of Units:** 2      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	20,000 GAL	Steel		I	NO
ST002	STORAGE FACILITY ST002	Ground	20,000 GAL	Fiberglass		A	NO

### Distribution System

Pump Type	Total Dyn Head ft H2O    P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	830 FT WELL	Active	WL	8	10 GPM		Yes	GW	Permanent	1/1 to 12/31	

\*Reports measured flow for wells, approved design capacity for all other sources.